

420-0004-048		Sht. 1 of 1	APP'D BY SGA
ISSUE	EDONO.	APPD	DATE
3	11-01-246	SGA	12/14/01
4	5-02-211	SGA	6-6-02

## Declaration of Conformity

We

**AMETEK DREXELBROOK  
205 KEITH VALLEY ROAD  
HORSHAM, PENNSYLVANIA  
USA 19044**

declare under our sole responsibility that the product LCT Point Level Measuring System Model Number 506/406-6200 Series, to which this declaration relates is in conformity with the following standards and entitled to carry the CE Mark:

**Product Type: Generic Heavy Industrial**


*Following the provisions of 89/336 EEC Directive,*

**Conforms to the emissions requirements of:**

EN 55011:1998 Class A, Conducted Emissions 150 kHz to 30 MHz  
EN 55011:1998 Class B, Radiated Emissions, 30MHz to 1GHz

**Conforms to the immunity requirements of EN 61000-6-2:1999:**

EN 61000-4-2:1995 Electrostatic Discharge  
EN 61000-4-3:1997 Radiated Immunity  
ENV 50204:1994 Radiated Immunity, Pulsed  
EN 61000-4-4:1995 EFT/Burst, Power and I/O Leads  
EN 61000-4-5:1995 Surge Immunity, Power Leads  
EN 61000-4-6:1996 Conducted Immunity, Power and I/O Leads  
EN 61000-4-8:1994 Power Frequency Magnetic Fields (10 A(rms)/meter)  
EN 61000-4-11:1994 Voltage Dips and Interrupts



Steven G. Arnold

Quality Assurance & Product Safety Manager

Issue Date 4/01/2002