

# CERTIFICATE OF CONFORMITY



- HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS**
- Certificate No:** FM17CA0114X
- Equipment:** R\*L2-\*\*\*\*, R\*L2-0\*\*\*, R\*T2-\*0\*\*, R\*T2-00\*\*, S\*R\*L2-\*\*\*\*, S\*R\*L2-0\*\*\*, S\*R\*T2\*0\*\*, and S\*R\*T2-00\*\* IntelliPoint RF Transmitter with Integral and Remote Sensor
- Name of Listing Company:** AMETEK Drexelbrook
- Address of Listing Company:** 205 Keith Valley Road  
Horsham, PA 19044  
USA
- The examination and test results are recorded in confidential report number:  

3014052C dated 1<sup>st</sup> February 2002
- FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:  

CSA-C22.2 No. 25:1966, CSA-C22.2 No. 30:1986, CSA-C22.2 No. 94:1991,  
CSA-C22.2 No. 142:1987, CSA-C22.2 No. 157:1992, CSA-C22.2 No. 213:R2013
- If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
- This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.

**Certificate issued by:**

  
\_\_\_\_\_  
J.E. Marquedant  
VP, Manager - Electrical Systems

30 July 2019  
\_\_\_\_\_  
Date

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA  
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

<b>420-0004-406</b>		Sht 1 of 5	ISSUE 7
<b>ISSUE</b>	<b>EDO NO</b>	<b>APPD</b>	<b>DATE</b>
7	8-19-100	SGA	8-13-19

# SCHEDULE



Canadian Certificate Of Conformity No: FM17CA0114X

10. Equipment Ratings:

Explosionproof for use in Class I, Division 1, Groups A, B, C and D; Dust-Ignitionproof for use in Class II and III, Division 1, Groups E, F and G; Nonincendive for use in Class I, Division 2, Groups A, B, C and D; Suitable for use in Class II and III, Division 2, Groups F and G Hazardous (Classified) Indoor and Outdoor (Type 4, 4X, IP66) Locations with Intrinsically Safe connections to Class I, II and III, Division 1, Groups A, B, C, D, E, F and G Hazardous (Classified) Locations in accordance with Control Drawing 420-0004-144-CD for the RxLx Series and Control Drawing 420-0004-173-CD for the RxTx and SxRx Series; Intrinsically Safe for use in Class I, II and III, Division 1, Groups A, B, C, D, E, F and G Hazardous (Classified) Locations in accordance with entity requirements and control drawing 420-0004-173-CD.

11. The marking of the equipment shall include:

**IntelliPoint Transmitter with Remote Sensor, IntelliPoint Transmitter with Integral Sensor, SIL IntelliPoint Transmitter with Remote Sensor, and SIL IntelliPoint Transmitter with Integral Sensor**  
XP WITH IS SENSING ELEMENT FOR CLI, DIV 1, GP B, C, D, DIP FOR CL II, DIV 1, GP E, F, G, AND CL III, DIV 1, SUITABLE FOR CL I, II, III, DIV 2 GP A, B, C, D, E, F, G WITH IS SENSING ELEMENT FOR CL I, II, III, DIV 1, GP A-G  
T5 @ +176°F/+70°C MAX. AMB. INSTALL PER 420-0004-144-CD

**IntelliPoint Two-Wire Transmitter with Remote Sensor, IntelliPoint Two-Wire Transmitter with Integral Sensor, SIL IntelliPoint Two-Wire Transmitter with Remote Sensor and SIL IntelliPoint Two-Wire Transmitter with Integral Sensor**  
XP FOR CLI, DIV 1, GP B, C, D, DIP FOR CL II, DIV 1, GP E, F, G, AND CL III, DIV 1, SUITABLE FOR CL I, II, III, DIV 2 GP A, B, C, D, E, F, G IS APPROVED FOR CL I, II, III, DIV 1, GP A-G  
T5 @ +176°F/+70°C MAX. AMB. INSTALL PER 420-0004-173-CD

**700-a, IntelliPoint Sensors.**  
IS APPROVED FOR CL I, II, III, DIV 1, GP A-G  
T5 @ +176°F/+70°C MAX. AMB.

12. Description of Equipment:

**General** - The Intellipoint RF Point Level System consists of a Model RNL3 series transmitter, a 700 series level sensor and a 380 series connecting cable used for the remote version of the probe. The system using the remote sensor may also include an RF filter (401-0016-024). The transmitter provides intrinsically safe outputs to the sensing elements. It converts a capacitive level measurement into a relay contact signal.

**Construction** - The Intellipoint RF Point Level System consists of a dual-compartment electronics housing with thread-on window cover and either an intergaral or remote probe assembly.

**Ratings** - The Intellipoint RF Point Level System operates at 21-100 Vdc, 85-250 Vac (2W) or 13-30 Vdc (1W). The transmitters and probes are rated for use in an ambient temperature range of -25°C to +70°C.

***RaLb-cdef, IntelliPoint Transmitter with Remote Sensor.***

a = Calibration: N, M, H, G, L, T, V or P

b = Seal Option; 3, 7, or B

c = Cable length: 1 - 9, A - K.

d = Relays: 1 or 2

e, f = Sensing Elements: 00, 02 - 04, 06, 07, 09 - 22, 24 - 28, 31 - 40, 50 - 53, 55, 60 - 62, 64, 66, 67, 72, 73, 80 - 83, 85, 90 - 94, NN, or ZZ.

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA  
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmapprovals.com](mailto:information@fmapprovals.com) [www.fmapprovals.com](http://www.fmapprovals.com)

## SCHEDULE



Canadian Certificate Of Conformity No: FM17CA0114X

***RaLb-0cde. IntelliPoint Transmitter with Integral Sensor.***

- a = Calibration: N, M, H, G, L, T, V or P
  - b = Seal Option: 3, 7, or B
  - c = Relays: 1 or 2
  - d, e = Sensing Elements: 00, 02 - 04, 06, 07, 09, 11 - 19, 21, 22, 24, 25, 28, 67, 72, 73, 86, 87, 90 - 93, NN, or ZZ.
- \*Sensors are Intrinsically Safe for Class I, II, III, Division 1, Groups A-G.

***RaTb-c0de. IntelliPoint RF Two-Wire Level Transmitter with Remote Sensor***

- a = Calibration: N, M, H, G, L, T, V, or P
- b = Seal Option: 3, 7, or B
- c = Cable Length: 1 - 9, A - K
- d, e = Sensing Element: 00, 02 - 04, 06, 07, 09 - 22, 24, 25 - 28, 31 - 40, 50 - 53, 55, 60 - 62, 64, 66, 67, 72, 73, 80 - 83, 85, 90 - 94, NN, or ZZ.

Entity Parameters:

Vmax = 30V, Imax = 140 mA, Pi = 1 W, Ci = 0, Li = 145 µH

***RaTb-00cd. IntelliPoint RF Two-Wire Level Transmitter with Integral Sensor***

- a = Calibration N, M, H, G, L, T, V, P or R
  - b = Seal Option; 3, 7, B
  - c, d = Sensing element: 00, 02 - 04, 06, 07, 09, 11 - 19, 21, 22, 24, 25, 28, 67, 72, 73, 86, 87, 90 - 93, NN, or ZZ.
- \*Sensors are Intrinsically Safe for Class I, II, III, Division 1, Groups A-G

Entity Parameters:

Vmax = 30V, Imax = 140 mA, Pi = 1 W, Ci = 0, Li = 145 µH

***SaRbLc-defg. SIL IntelliPoint Transmitter with Remote Sensor.***

- a = SIL Level: SIL evaluation not performed by FM Approvals
- b = Calibration: N, H, L, T, V or P
- c = Seal Option; 3, 7, or B
- d = Cable length: 1 - 9, A - K
- e = Relays: 1 or 2
- f, g = Sensing Elements: 00, 02, 04, 06, 07, 09, 11 - 21, 24 - 28, 60 - 62, 64, 66, 67, 72, 73, 85, 90 - 94.

***SaRbLc-0def. SIL IntelliPoint Transmitter with Integral Sensor.***

- a = SIL Level: SIL evaluation not performed by FM Approvals
  - b = Calibration: N, H, L, T, V or P
  - c = Seal Option: 3, 7, or B
  - d = Relays: 1 or 2
  - e, f = Sensing Elements: 00, 02, 04, 06, 07, 09, 11 - 19, 21, 24, 25, 28, 67, 72, 73, 86, 87, 90 - 93.
- \*Sensors are Intrinsically Safe for Class I, II, III, Division 1, Groups A-G.

***SaRbTcd0ef. SIL IntelliPoint Two-Wire Transmitter with Remote Sensor.***

- a = SIL Level: SIL evaluation not performed by FM Approvals
- b = Calibration: N, H, L, T, V, or P.
- c = Seal Option: 3, 7, or B.
- d = Cable Length: 1 - 9, A - K.
- e, f = Sensing Element: 00, 02, 04, 06, 07, 09, 11 - 21, 24 - 28, 60 - 62, 64, 66, 67, 72, 73, 85, 90 - 94.

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA  
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmapprovals.com](mailto:information@fmapprovals.com) [www.fmapprovals.com](http://www.fmapprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM17CA0114X

**Entity Parameters:**

Vmax = 30V, Imax = 140 mA, Pi = 1 W, Ci = 0, Li = 145 µH

**SaRbTc-00de. SIL IntelliPoint Two-Wire Transmitter with Integral Sensor**

a = SIL Level: SIL evaluation not performed by FM Approvals

b = Calibration: N, H, L, T, V, or P.

c = Seal Option: 3, 7, or B.

d, e = Sensing Element: 00, 02, 04, 06, 07, 09, 11 – 19, 21, 24, 25, 28, 67, 72, 73, 86, 87, 90 – 93.

\*Sensors are Intrinsically Safe for Class I, II, III, Division 1, Groups A-G

**Entity Parameters:**

Vmax = 30V, Imax = 140 mA, Pi = 1 W, Ci = 0, Li = 145 µH

**700-a, IntelliPoint Sensors.**

a = Any 7 digit numeric combination maintaining the limits of 420-0004-144-CD or 420-0004-173-CD.

**13. Specific Conditions of Use:**

**IntelliPoint Transmitter with Remote Sensor, IntelliPoint Transmitter with Integral Sensor, SIL IntelliPoint Transmitter with Remote Sensor, and SIL IntelliPoint Transmitter with Integral Sensor**

1. The equipment shall not be applied in an explosive dust atmosphere where high electrostatic charging processes are present that could result in propagating brush discharges. See IEC TS60079-32-1 for additional guidance.
2. Consult the manufacturer if dimensional information on the flameproof joints is necessary.

**IntelliPoint Two-Wire Transmitter with Remote Sensor, IntelliPoint Two-Wire Transmitter with Integral Sensor, SIL IntelliPoint Two-Wire Transmitter with Remote Sensor and SIL IntelliPoint Two-Wire Transmitter with Integral Sensor**

1. The enclosure contains aluminum and is considered a potential risk of ignition by impact or friction. Care must be taken into account during installation and use to prevent impact or friction.
2. The equipment shall not be applied in an explosive dust atmosphere where high electrostatic charging processes are present that could result in propagating brush discharges. See IEC TS60079-32-1 for additional guidance.

**14. Test and Assessment Procedure and Conditions:**

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

**15. Schedule Drawings**

A copy of the technical documentation has been kept by FM Approvals

**16. Certificate History**

Details of the supplements to this certificate are described below:

Date	Description
1 <sup>st</sup> February 2002	Original Issue.
9 <sup>th</sup> July 2017	<u>Supplement 15:</u> Report Reference: – RR210041 dated 9 <sup>th</sup> July 2017.

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA  
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmapprovals.com](mailto:information@fmapprovals.com) [www.fmapprovals.com](http://www.fmapprovals.com)

## SCHEDULE



Canadian Certificate Of Conformity No: FM17CA0114X

	Description of the Change: Minor changes to circuitry and certificate updated to new format.
7 <sup>th</sup> February 2018	<u>Supplement 16:</u> Report Reference: – RR212335 Dated 7 <sup>th</sup> February 2018. Description of the Change: Adding SIL versions of line powered versions, adding additional sensors.
30 <sup>th</sup> July 2018	<u>Supplement 17:</u> Report Reference: – RR214288 Dated 30 <sup>th</sup> July 2018. Description of the Change: Added specific conditions of use for the equipment.
30 <sup>th</sup> July 2019	<u>Supplement 18:</u> Report Reference: – RR219205 Dated 30 <sup>th</sup> July 2019. Description of the Change: Sensing element 67 added.

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA  
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

F 348 (Mar 16)

Page 5 of 5

420-0004-406

Sht 5  
of 5

ISSUE 7