



△ NOTES:

1. SHOWN WITH INTELLIPOINT SYSTEM.
2. MAXIMUM INSERTION LENGTH 25' (7620 mm).
THERE IS 2' (610 mm) OF ADDITIONAL CABLE IN THE CABLE HOUSING.
3. MAXIMUM OF 15' (4572 mm) COILED IN CABLE HOUSING.

CERTIFIED by _____					COPYRIGHT 2018 AMETEK DREXELBROOK		OVERFILL PROTECTION SENSING ELEMENT
PO # _____					SCALE NONE UNLESS OTHERWISE STATED ALL DIMENSIONS IN INCHES (MM)		
ENG _____					DR. TDH 2-27-18	205 KEITH VALLEY RD HORSHAM, PA 19044-9986 215-674-1234 FAX 215-674-2731	700-0005-595-CD
USER _____					CK. JEN 2-27-18		
DE # _____	1	2-18-118	TDH	2-27-18	ISS. EDO/DSR NO. APP'D DATE	ISS. 1	

No. 700-0005-595-CD
 SHT 1 OF 1